

Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

The Principal
Sant Bal Yogeshwar Vidya
Mandir Sec. School Dadwara (Phinter)
Tehsil Billawar, District Kathua

No: JDF&ES/FPI 5491

Dated: 15.12.2020

~~Sub: Fire Safety Certificate.~~


~~Ref: Your Office letter No.SBYBVM/F-19/2020-21/330 dated 11.09.2020.~~

Dear Sir,

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed Hose Reel Hose and First Aid Fire Extinguishers in their school premises. The school is about 65 Km away from Fire & Emergency Station Kathua and is approachable for fire tender in case of any emergency. Since the school is already functioning as such, the management can proceed ahead for operation subject to adopt the following fire safety precautionary measures in letter and spirit for effective and betterment of the school:-

1. All exists/staircase should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
2. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/ operating of fire fighting system installed in the school building. The management shall intimate the office of Assistant Director, Fire & Emergency Services Command Samba - Kathua after each quarter that the fire fighting equipments installed in the school are functioning.
3. No Hazardous material should be kept inside or outside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance will be treated withdrawn/cancelled.
4. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
5. The corridor of the building shall not be used for any kind of storage.
6. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
7. At present school is having two blocks, one is four storied and another is double storied. As such no addition/alteration should be made by the school management in the existing structure without prior permission from this department.
8. The validity of this clearance shall remain in force for one year and same needs to be renewed after checking of fire fighting system installed in the school.

Yours sincerely


Joint Director
Fire & Emergency Services
Jammu Range, Jammu